

OVERHEAD RIGHT-OF-WAY CLEARANCE SPECIFICATIONS

Crawford Electric Cooperative

New construction rights of way shall have the utility corridor cleared to a minimum of 15 feet on each side of the proposed primary line circuits, for a total cleared width of at least 30 feet. All trees trimmed at the edge of the right of way shall be trimmed vertical from ground to sky with **NO** overhanging limbs in the right-of-way corridor.

All trees, brush and stumps cleared from the right of way shall be cut as low to the ground as possible with the terrain. The remaining stump height shall not exceed 4 inches on the uphill side. All logs, brush and stumps shall be disposed of or windrowed (piled) off the 30 foot right of way in a neat manner as coordinated with all property owners involved. Newly cleared right of way must pass a Cooperative inspection before line construction begins.

EFFECTIVE DATE: March 1, 2007

